



Regulation Electrical Requirements

Essential requirements for electrical assembler's subcontractors in exhibition area

1. All wiring or electrical installation, a floor flush should be with rough use wire, caliber # 12 minimum.
2. The contacts to be polarized duplexes and be protected with the sloop box and / or the "FS" type conduit box with its respective connector and cover.
3. Thermomagnetic and / or fuse protections must be of Provided by the WTC International Exhibition and Convention Center
4. All wiring that has to cross the aisles for any Protect yourself with carpet and traffic tape to prevent accidents.
5. Every installation for fluorescent lighting must be adequate, without cables welded directly to the lamps or enabled in wood; These should be standardized luminaires.
6. The mooring or splicing is not permitted for safety reasons. To pins, and also the ties or joints must be made inside a registration box.
7. The cable used must be of the appropriate size according to the installed capacity of your electrical equipment.
8. All areas of electrical rooms, hydrants, telecommunications rooms, shall not be obstructed by screens or material of any kind.
9. Floor level moorings are not allowed for traffic places such as aisles, booth access and risk areas, where a short circuit can be generated.

In case of not complying with these guidelines, the CIECWTC will be granted the right to withdraw the electric energy from the stands that, according to them, do not comply with the rules in common agreement with the organizing committee